NESANS

MAINTENANCE TIPS

Jaw Crusher Eccentric Shaft Bearing Maintenance: Prevent Catastrophic Failures

Protect your jaw crusher investment with proper eccentric bearing care. Lubrication schedules, temperature monitoring, and failure warning signs.

Author: Sivabalan Selvarajan

Published: January 31, 2026

Reading Time: 3 minutes

Eccentric shaft bearings are the heart of jaw crusher operation—their failure stops production instantly and costs ₹5-15 lakhs in parts plus days of downtime. Yet 80% of premature bearing failures result from preventable causes: lubrication failure, contamination, and overloading. This guide establishes maintenance protocols that achieve 15,000-25,000 operating hours from bearings designed for 10,000-hour service life.

Understanding Eccentric Shaft Bearing Loads

Load Components

LOAD TYPE	SOURCE	MAGNITUDE	BEARING IMPACT
Radial crushing force	Material compression	500-2000 kN	Primary fatigue load

LOAD TYPE	SOURCE	MAGNITUDE	BEARING IMPACT
Gyrating motion	Eccentric rotation	Continuous cycling	Fatigue stress
Axial thrust	Toggle plate angle	50-200 kN	Thrust bearing load
Impact shock	Large feed, tramp metal	Variable spikes	Surface damage

Lubrication System Requirements

Oil Bath System Specifications

PARAMETER	SPECIFICATION	CONSEQUENCE IF WRONG
Oil type	ISO VG 150-220 EP	Insufficient film, accelerated wear
Oil level	Sight glass center	Low: starvation; High: churning heat
Temperature	40-70°C operating	>80°C indicates problems
Change interval	2000-3000 hours or annually	Contamination buildup

Circulating Oil System

COMPONENT	CHECK POINT	ACTION
Oil pump	Flow rate and pressure	Verify per specification
Filter	Pressure differential	Replace when ΔP > 1 bar
Cooler	Outlet temperature	Clean if Δ >15°C from ambient
Flow switch	Operation test	Must stop crusher on low flow

Daily Inspection Protocol

CHECK	METHOD	NORMAL	ACTION THRESHOLD
Oil level	Sight glass	Center mark	Add oil if low

CHECK	METHOD	NORMAL	ACTION THRESHOLD
Oil condition	Visual through sight glass	Clear, amber color	Investigate milky or dark
Bearing temperature	IR thermometer	40-70°C	>80°C: stop and investigate
Unusual noise	Listening	Smooth operation	Any grinding or knocking
Vibration	Touch or meter	Consistent pattern	Increased or irregular

Oil Analysis Program

TEST	FREQUENCY	NORMAL LIMITS	INDICATES
Viscosity	Quarterly	±10% of new oil	Degradation or contamination
Water content	Quarterly	<0.1%	Seal leakage, condensation
Iron particles	Quarterly	<50 ppm	Bearing/gear wear
Copper particles	Quarterly	<20 ppm	Bushing wear
Silica	Quarterly	<15 ppm	Dust contamination

Bearing Replacement Indicators

INDICATOR	MEASUREMENT	REPLACE WHEN
Radial clearance	Dial indicator	>0.3mm increase from new
Temperature trend	Daily log	Progressive increase >10°C
Oil analysis metals	Lab results	Iron >100ppm or increasing trend
Noise/vibration	Observation	Any significant change
Operating hours	Hour meter	Plan replacement at 15,000-20,000 hrs

Replacement Procedure Summary

1. Plan replacement during scheduled downtime (24-48 hour job)
2. Document all clearances before disassembly
3. Clean all surfaces meticulously before assembly
4. Pre-heat bearing inner races for installation
5. Verify all clearances match specifications
6. Fill with fresh oil and bleed air from system
7. Run at reduced load for break-in period

Conclusion

Eccentric shaft bearings respond predictably to proper maintenance. Consistent lubrication, temperature monitoring, and oil analysis catch developing problems before catastrophic failure. Plants that follow these protocols achieve 15,000-25,000 hours between bearing replacements—more than doubling the value from this critical investment while avoiding the unplanned downtime that devastates production schedules and profitability.

Topics: #Bearings #Jaw Crusher #Lubrication #Maintenance

NESANS
www.nesansindia.in
SF No 20/1, Eachanary Madukkarai Road, Coimbatore, TN 641024
+91 9578 799 755